


J10C - ACO COVERCOM® SCEC (SL2) - concrete pit & steel lid




Cable pit - full body





Cable pit - split body



- **Key**① Clear working dimension at pit base
- Clear working dimension at pit opening
 Clear working dimension beneath lid rebate

J10C - ACO COVERCOM® SCEC (SL2) - concrete pit & steel lid

Cable pits and lids

Description	Part	SEEPL	Internal Opening	Weight
	No.	Code	L x W x D (mm)	(kg)
J10C - full body pit only	142279	-	1905 x 440 x 900	1,117
J10C - split body pit only	142280	-	1905 x 440 x 885	1,105
P10C - steel lid (Class D)	143132	J10C		102

Accessories & ancillary items

Description	Part	Weight
	No.	(kg)
Lid Lifting Tool	142232	0.5
ID Plates	On Enquiry	N/A
Route Marker Plates	On Enquiry	N/A
SCEC (SL3) Padlocks	On Enquiry	0.5
Swing Arm	On Enquiry	1
SCEC (SL2) approved precast concrete riser	On Enquiry	Variable

Specifications

General

The cable pit shall be ACO J10C COVERCOM® SCEC (SL2) - concrete pit & steel lid - full* / split* body with Class D240kN (AS 3996) lids as supplied by ACO Pty Ltd. or equal approved.

The pit is fully tested and assessed on behalf of SCEC. SCEC have subsequently endorsed the lids and pits to SL2 contingent on the use of SCEC (SL3) padlocks to secure the lids.

Materials

The pit body shall be manufactured from reinforced cement concrete with:

Compressive strength: 40MPa

The nominal clear opening shall be 1,905mm x 440mm. Units shall be manufactured with an internal depth of 900mm* / 885mm* for full* / split* body pits.

Lid

The pit shall be covered with a SCEC (SL2) approved tamper evident locking steel lid. All lids must be load certified to AS 3996 and NATA test certificates must be supplied.

Installation

The cable pit shall be installed in accordance with the manufacturer's installation instructions and recommendations.

* delete as applicable

ACO Pty Ltd Australia

Ph: 1300 765 226 www.acoaus.com.au



sales@acoaus.com.au